

Rules for Construction of Fusion Energy Devices

This is a Draft Standard for Trial Use and Comment. This Draft Standard is not an approved consensus standard of ASME nor is it an American National Standard. ASME has approved its issuance and publication as a Draft Standard only. Distribution of this Draft Standard for comment shall not continue beyond 3 years from the date of issuance. The content of this Draft Standard for Trial Use and Comment was not approved through ASME's consensus process. Following the 3-year trial and comment period, this Draft Standard, along with comments received, will be submitted to a Consensus Committee or Project Team. The Consensus Committee or Project Team will review and revise this Draft Standard based, in part, upon experience during the trial term and resulting comments. A public review in accordance with established American National Standards Institute (ANSI) procedures is required at the end of the Trial-Use Period and before a Draft Standard for Trial Use is submitted to ANSI for approval as an American National Standard. Thereafter, it is expected that this Draft Standard (including any revisions thereto) will be submitted to ANSI for approval as an American National Standard. Suggestions for revision should be directed to the Chair, Subgroup on Fusion Energy Devices, using the following form: <http://go.asme.org/FE1CommentForm>.



Date of Issuance: November 30, 2018

This Draft Standard for Trial Use will be revised following the conclusion of the Trial-Use Period. There will be no written interpretations of the requirements of this Draft Standard for Trial Use issued.

ASME is the registered trademark of The American Society of Mechanical Engineers.

The Standards Committee that approved the Draft Standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a (draft) standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or (draft) standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this draft standard.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2018 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword		v
Committee Roster		vi
Subsection FA	Fusion Energy Device Facilities	1
Subpart FAA	General Requirements	2
Article FAA-1000	Introduction	2
FAA-1100	General	2
FAA-1110	Scope	2
FAA-1120	Definitions	2
FAA-1130	Limits of These Rules	2
FAA-1300	Fusion Technologies	2
Article FAA-2000	Classification of Components and Supports	6
FAA-2100	General Requirements	6
FAA-2120	Purpose of Classifying Items in a Fusion Power Plant	6
FAA-2130	Classifications and Rules of ASME FE.1	6
Article FAA-7000	Reference Standards	7
FAA-7100	General Requirements	7
Article FAA-8000	Certificates, Nameplates, Certification Mark, and Data Reports	8
FAA-8100	Authorization to Perform ASME BPVC Activities	8
Article FAA-9000	Glossary	9
FAA-9100	Introduction	9
FAA-9200	Definitions	9
Subpart FAB	Magnetic Confinement	10
Article FAB-1000	Introduction	10
FAB-1100	Scope	10
FAB-1200	Magnetic Confinement	10
FAB-1210	Magnet System	10
FAB-1220	Magnet Structures	12
FAB-1300	Vacuum Vessel	12
FAB-1310	Functional Requirements	12
FAB-1320	Vessel Shells	12
FAB-1330	Port Structures	13
FAB-1340	Supports and Mechanical Interfaces	13
FAB-1350	Cooling	13
FAB-1360	Loading Conditions	13
FAB-1400	In-Vessel Components	13
FAB-1410	Divertor	13
FAB-1420	Blanket	13
Subsection FB	Pressure Boundary Components	15

Subpart FBA	Magnet	16
Article FBA-1000	Introduction	16
FBA-1100	Scope	16
FBA-1110	Aspects of Construction Covered by These Rules	16
FBA-1120	Temperature Limits	16
FBA-1130	Boundaries of Jurisdiction Applicable to This Subsection	16
FBA-1140	Electrical and Mechanical Penetration Assemblies	16
Article FBA-2000	Material	17
FBA-2100	General Requirements for Material	17
FBA-2110	Scope of Principal Terms Employed	17
FBA-2120	Pressure-Retaining Material	17
FBA-2130	Certification of Material	18
FBA-2140	Welding Material	18
FBA-2150	Material Identification	18
FBA-2160	Deterioration of Material in Service	18
FBA-2170	Heat Treatment to Enhance Impact Properties	18
FBA-2180	Procedures for Heat Treatment of Material	18
FBA-2190	Non-Pressure-Retaining Material	19
FBA-2200	Material Test Coupons and Specimens for Ferritic Steel Material	19
FBA-2210	Procedure for Obtaining Test Coupons and Specimens for Quenched and Tempered Material	19
FBA-2300	Welding Material	19
FBA-2310	General Requirements	19
FBA-2400	Dimensional Standards	19
Article FBA-3000	Design	20
FBA-3100	General Design	20
FBA-3110	Loading Criteria	20
FBA-3200	Design by Analysis	20
 Nonmandatory Appendix		
A	Topics in Development	21
 Figures		
FAA-1300-1	A Typical Light Water Fission System	3
FAA-1300-2	A Theoretical Magnetic Confinement-Based Fusion System	5
FAB-1210-1	Example of a Magnet Confinement System in an ITER Machine	11
 Table		
FAA-7100-1	Standards Referenced in ASME FE.1 Associated With Fusion Components	7

FOREWORD

There is an ongoing effort within The American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel (BPV) Committee on Construction of Nuclear Facility Components (Section III) to develop rules for the construction of fusion energy devices. The Standards Committee of Section III, Division 4 and its Subgroup on Fusion Energy Devices (FED) are developing these new fusion Code rules. These rules cover fusion-energy-related components such as vacuum vessels, cryostats, and superconducting magnet structures and the interactions of these components. Related support structures, including metallic and nonmetallic materials, containment or confinement structures, and in-vessel components such as fusion-system piping, vessels, valves, pumps, and supports, are also covered. The rules contain requirements for materials, design, fabrication, testing, examination, inspection, certification, and stamping.

ASME BOILER AND PRESSURE VESSEL COMMITTEE ON CONSTRUCTION OF NUCLEAR FACILITY COMPONENTS (BPV III)

(The following is the roster of the Committee at the time of approval of this Draft Standard.)

STANDARDS COMMITTEE OFFICERS

R. Hill III, *Chair*
R. Keating, *Vice Chair*
J. Minichiello, *Vice Chair*
A. Byk, *Staff Secretary*

STANDARDS COMMITTEE PERSONNEL

T. Adams , Jensen Hughes	J. Minichiello , Bechtel National, Inc.
A. Appleton , Alloy Stainless Products Co., Inc.	M. Mitchell , USNC
R. Barnes , Anric Enterprises, Inc.	M. Morishita , Japan Atomic Energy Agency
W. Borter , Consultant	D. K. Morton , Consultant
C. Bruny , Consultant	T. Nagata , Hitachi-GE Nuclear Energy Ltd.
T. Burchell , Oak Ridge National Laboratory	J. Nestell , MPR Associates
A. Byk , The American Society of Mechanical Engineers	E. L. Pleins , Westinghouse Electric Co.
P. Deubler , Becht Engineering Co., Inc.	R. Reedy, Sr. , Reedy Engineering, Inc.
P. Donavin , DTE Energy, Fermi Nuclear Power Station	I. Saito , Japan Nuclear Safety Institute
A. Eberhardt , Sargent & Lundy, LLC	S. Sham , Argonne National Laboratory
R. Hill III , Hill Engineering Solutions	W. Sowder, Jr. , Quality Management Services Co., LLC
S. Hunter , Framatome, Inc.	W. Sperko , Sperko Engineering Services, Inc.
R. Jessee , Babcock & Wilcox	J. Tucker , Flowserve
B. Jetter , Consultant	C. Withers , National Board of Boiler and Pressure Vessel Inspectors
R. Keating , MPR Associates, Inc.	H.-T. Wang , <i>Delegate</i> , Tsinghua University Institute of Nuclear and New Energy Technology
C. Kim , Westinghouse Electric Co.	C. Smith , <i>Contributing Member</i> , Smith Associates Consulting Group, LLC
G. H. Koo , Korea Atomic Energy Research Institute	M. Zhou , <i>Contributing Member</i> , China Nuclear Power Design Co. Ltd.
M. Lockwood , Hartford Steam Boiler	
K. Manoly , U.S. Nuclear Regulatory Commission	
D. Matthews , Framatome, Inc.	

SUBGROUP ON FUSION ENERGY DEVICES (BPV III-4)

W. Sowder, Jr. , <i>Chair</i> , Quality Management Services Co., LLC	X. Li , Institute for Standardization of Nuclear Industry
D. Roszman , <i>Secretary</i> , Hayward Tyler, Inc.	P. Mokaria , ITER-India
M. Bashir , Culham Centre for Fusion Energy	T. R. Muldoon , American Exchanger Services, Inc.
L. C. Cadwallader , Battelle Energy Alliance, LLC	M. Porton , Culham Centre for Fusion Energy
B. R. Doshi , Institute for Plasma Research	F. Schaaf, Jr. , Sterling Refrigeration Corp.
G. Holtmeier , Lawrence Livermore National Laboratory	P. Smith , Consultant
K. Kavanagh , U.S. Nuclear Regulatory Commission	Y. Song , Institute of Plasma Physics, Chinese Academy of Sciences
K. Kim , National Fusion Research Institute	M. Trosen , Major Tool & Machine, Inc.
I. Kimihiro , Toyama Co. Ltd.	C. Waldon , UK Atomic Energy Authority
S. Lee , National Fusion Research Institute	I. Zatz , Princeton University Plasma Physics Laboratory
G. Li , Institute for Standardization of Nuclear Industry	R. Barnes , <i>Contributing Member</i> , Anric Enterprises, Inc.

WORKING GROUP ON GENERAL REQUIREMENTS (BPV III-4)

D. Roszman , <i>Chair</i> , Hayward Tyler, Inc.	W. Sowder, Jr. , Quality Management Services Co., LLC
--	--

WORKING GROUP ON IN-VESSEL COMPONENTS (BPV III-4)

M. Bashir, *Chair*, Culham Centre for Fusion Energy
Y. Carin, Fusion for Energy

M. Kalsey, UK Atomic Energy Authority

WORKING GROUP ON MAGNETS (BPV III-4)

S. Lee, *Chair*, National Fusion Research Institute

K. Kim, *Vice Chair*, National Fusion Research Institute

WORKING GROUP ON MATERIALS (BPV III-4)

M. Porton, *Chair*, Culham Centre for Fusion Energy

P. Mummery, University of Manchester School of Mechanical Engineering

WORKING GROUP ON VACUUM VESSELS (BPV III-4)

I. Kimihiro, *Chair*, Toyama Co. Ltd.
L. C. Cadwallader, Battelle Energy Alliance, LLC
B. R. Doshi, Institute for Plasma Research

Q. Shijun, Institute of Plasma Physics, Chinese Academy of Sciences
Y. Song, Institute of Plasma Physics, Chinese Academy of Sciences

INTENTIONALLY LEFT BLANK

SUBSECTION FA

FUSION ENERGY DEVICE FACILITIES

SUBPART FAA

GENERAL REQUIREMENTS

ARTICLE FAA-1000

INTRODUCTION

FAA-1100 GENERAL

FAA-1110 Scope

The rules of [Subsection FA, Subpart FAA](#) constitute the general requirements associated with fusion components used in the construction of fusion devices and their supporting systems. Only those fusion components that are serving a pressure boundary and/or structural integrity function (see [FAA-2120](#)) are covered by these rules. Items that are specifically excluded are electrical components and superconducting strand. It is understood that these rules were developed to document rules for construction that are not adequately addressed within existing Divisions of Section III of the ASME Boiler and Pressure Vessel Code (BPVC) or other existing codes and standards used in the nuclear industry.

(a) The General Requirements of ASME FE.1 are provided in ASME BPVC, Section III, Subsection NCA, except for those paragraphs or subparagraphs (with numbered headers) replaced by corresponding numbered FAA paragraphs or subparagraphs or new numbered FAA paragraphs or subparagraphs.

(b) ASME BPVC, Section III, Division 1 terminology may differ from that in ASME FE.1 (e.g., Class 1 and Class 2 versus Class A and Class B), but the application and use of these rules are identical for ASME FE.1 construction except where otherwise noted.

(c) References to Appendices are to each respective Subsection of this Draft Standard, unless otherwise stated.

FAA-1120 Definitions

Definitions of key terms specific to this Draft Standard are included in [Article FAA-9000](#) or noted within the applicable text. The definitions in [Article FAA-9000](#) shall prevail should a conflict exist with definitions found in ASME BPVC, Section III, Subsection NCA or in other documents referenced in this Draft Standard. Unless a term is defined in [Article FAA-9000](#), the definition in ASME BPVC, Section III, Subsection NCA, Article NCA-9000 shall apply.

FAA-1130 Limits of These Rules

The rules of this Draft Standard for fusion components provide requirements for new construction and include consideration of mechanical and thermal stresses due to cyclic operation and high-temperature creep. These rules address the thermal and radiation effects on materials produced during the fusion activity. The rules do not cover deterioration that may occur in service as a result of corrosion, erosion, thermal embrittlement, or instability of material. These effects shall be taken into account with a view to realizing the design or the specified life of the components and support identified.

The rules are not intended to be applicable to valve operators, controllers, position indicators, pump impellers, pump drivers, or other accessories and devices, unless they are pressure-retaining parts or act as support structures or supports. If such items are in a support load path, the provisions of [FAA-1100](#) apply.

The rules of this Draft Standard do not apply to instruments, or permanently sealed fluid-filled tubing systems furnished with instruments, but they do apply to instrument, control, and sampling piping when specified in a Design Specification.


FAA-1300 FUSION TECHNOLOGIES

[Subsection FA](#) provides the rules for construction of nuclear fusion devices and their supporting systems. Nuclear fusion and nuclear fission are two different types of energy-releasing reactions in which energy is released from high-powered atomic bonds between the particles within a nucleus. The main difference between these two processes is that fission is the splitting of an atom into two or more smaller ones, whereas fusion is the fusing of two or more smaller atoms into a larger one.

Nuclear fission is a technology that has been in use since the 1950s. [Figure FAA-1300-1](#) illustrates a typical light water fission system. There is potential for new developments in nuclear energy technology to enhance nuclear energy's role in a sustainable-energy future.

Figure FAA-1300-1 A Typical Light Water Fission System

Nuclear power plant



© 2013 Encyclopædia Britannica, Inc.


GENERAL NOTE: Image courtesy of Encyclopædia Britannica, Inc., copyright 2013; used with permission.

Nuclear fusion is a process in which light nuclei, usually deuterium and tritium, collide and join together to form a heavier nucleus. When this happens, a considerable amount of energy is released. To overcome the electrostatic repulsion of these light nuclei so they will collide and fuse, extreme energy is imparted to the nuclei by radio-frequency heating, ohmic heating, neutral beam heating, or other means. These high-energy nuclei are called plasma ions. These plasma ions are confined by magnetic fields in a tokamak system so their velocity

energy allows them to collide. [Figure FAA-1300-2](#) illustrates a theoretical magnetic confinement-based fusion system.

Another fusion system is to freeze deuterium and tritium atoms into small pellets, and then heat and compress the frozen pellets with lasers or X-rays so that the inertia of the pellet mass allows atom collisions and fusion. Deuterium fuel is abundant in water, and tritium can be bred from lithium.

Figure FAA-1300-2 A Theoretical Magnetic Confinement-Based Fusion System



5

GENERAL NOTE: Image courtesy of the National Fusion Research Institute of Korea (NFRI).

ARTICLE FAA-2000

CLASSIFICATION OF COMPONENTS AND SUPPORTS

FAA-2100 GENERAL REQUIREMENTS

FAA-2120 Purpose of Classifying Items in a Fusion Power Plant

Construction rules are specified for items that are designated Code Classes A and B. These Code classes are to be applied to the classification of items in fusion energy devices and their supporting systems. Class A component rules address those items deemed to be serving a pressure boundary and/or structural integrity function, and Class B rules address those items deemed not to have a pressure boundary function but that do serve a structural integrity function. These classifications reflect the risk-based approach derived from safety criteria established for fusion-based devices. Items not in the two classifications listed above may be addressed in either these Draft Standard rules or appropriate non-nuclear codes and standards.

This Draft Standard recognizes the different levels of importance associated with the function of each item within fusion systems as related to the safe operation of the nuclear facility. The Code classes allow a choice of rules that provide assurance of structural integrity and quality commensurate with the relative importance assigned to the individual items of the nuclear facility.

FAA-2130 Classifications and Rules of ASME FE.1

FAA-2131 Code Classes of ASME FE.1. ASME FE.1 provides rules for the construction of items in the following Code classes:

- (a) Class A, which includes Class A components, supports for Class A components, and support structures
- (b) Class B, which includes Class B components and supports for Class B components

ARTICLE FAA-7000

REFERENCE STANDARDS

FAA-7100 GENERAL REQUIREMENTS

The standards and specifications referenced in the text of this Draft Standard associated with fusion components are listed in [Table FAA-7100-1](#), unless they are already listed in ASME BPVC, Section III, Divisions 1 and 2 or ASME BPVC, Section III, Subsection NCA, Table NCA-7100-2. The standards and specifications associated with nonmetallic components are addressed in their

respective Subparts of [Subsection FA](#). Where reference is made within ASME FE.1 to requirements that are part of the ASME BPVC, the BPVC Sections are not included in [Table FAA-7100-1](#). International standards, such as from the International Organization for Standardization (ISO) or the International Atomic Energy Agency (IAEA), may be used if specified by standards and specifications referenced in other codes and standards.

Table FAA-7100-1 Standards Referenced in ASME FE.1 Associated With Fusion Components

Standard ID	Published Title	Referenced Edition	Subsection Applicability
The American Society of Mechanical Engineers (ASME)			
ASME NQA-1	Quality Assurance Requirements for Nuclear Facility Applications	2015	All
American Society for Nondestructive Testing (ASNT)			
SNT-TC-1A	Personnel Qualification and Certification in Nondestructive Testing	2011	All

ARTICLE FAA-8000

CERTIFICATES, NAMEPLATES, CERTIFICATION MARK, AND DATA REPORTS

FAA-8100 AUTHORIZATION TO PERFORM ASME BPVC ACTIVITIES

The rules for certificates, nameplates, the Certification Mark, and Data Reports for fusion components, supports, and support structures under ASME FE.1 shall be the same as the rules established for ASME BPVC, Section III, Division 1 metallic components and metallic core support structures. The only changes shall be the use of ASME FE.1 terminology rather than Division 1 termi-

nology (e.g., Class A and Class B rather than Class 1 and Class 2) and the specification of the ASME FE.1 Subpart used.

Authorization to use the official Certification Mark or to certify work by other means provided in [Subpart FAA](#) (see ASME BPVC, Section III, Subsection NCA, Table NCA-8100-1) will be granted by the Society for a 3-yr period pursuant to the provisions set forth in ASME BPVC, Section III, Subsection NCA.

ARTICLE FAA-9000 GLOSSARY

FAA-9100 INTRODUCTION

This Article defines selected terms used in this Draft Standard for pressure boundary components, supports, and support structures. The definitions in this Glossary shall prevail should a conflict exist with definitions found in ASME BPVC, Section III, Division 1 or other documents referenced in this Draft Standard. Unless defined below, the definitions in ASME BPVC, Section III, Subsection NCA, Article NCA-9000 shall apply.

FAA-9200 DEFINITIONS

controlled nuclear fusion: the process of fusing nuclei together at a controlled rate. When fusing light nuclei such as deuterium (D) and tritium (T) isotopes, there is some excess mass that is converted to kinetic energy of the reaction products. For D + T, a helium nucleus and a neutron are produced in the fusion reaction. The kinetic energy of these fusion reaction products can be captured by slowing the reaction products in a material so that kinetic energy is converted to heat energy. The heat energy can be used for producing electricity or other industrial uses. The tokamak system is in contact with

the fluid and maintains the internal or external fluid pressure.

inertial confinement: a nuclear fusion method in which frozen pellets in a vacuum chamber are rapidly compressed with great force by laser beams, X-ray beams, or ion beams.

ITER: an international organization that manages the International Thermonuclear Experimental Reactor (ITER) project.

magnetic confinement: a nuclear fusion method in which nuclei in a vacuum chamber are guided at high velocity by magnetic fields and heated by microwave energy and/or other means so that the high velocity of the nuclei overcomes electrostatic repulsion and fusion reactions occur.

pressure boundary: area on the surface of a component that has been designed to accept the stresses created by internal or external forces as defined in the Design Specification. (See [FAA-2120](#).)

tokamak: a fusion system using the magnetic confinement method.

SUBPART FAB

MAGNETIC CONFINEMENT

ARTICLE FAB-1000

INTRODUCTION

FAB-1100 SCOPE

There are several methods to accomplish controlled nuclear fusion, two of which are discussed within this Draft Standard. One method is magnetic confinement, in which nuclei in a vacuum chamber are guided at high velocity by magnetic fields and heated by microwave energy and/or other means so that the high velocity of the nuclei overcomes electrostatic repulsion and fusion reactions occur. Another method, inertial confinement, uses tiny frozen pellets in a vacuum chamber; the pellets are rapidly compressed with great force by laser beams, X-ray beams, or ion beams. The beams ionize some molecules and the compression force creates a shock wave in the pellet; this overcomes electrostatic repulsion and the atoms fuse. Both magnetic confinement and inertial confinement control the fusion reaction by the amount of mass and the amount of energy input to the process, either by heating or by compression.

FAB-1200 MAGNETIC CONFINEMENT

The tokamak, or system of magnetic confinement used in today's experimental devices and that may be used in future power facilities, uses both resistive and superconducting magnets. The major systems that can make up the tokamak include

- (a) resistive and superconducting magnets, including but not limited to the following:
 - (1) toroidal field (TF) coils
 - (2) poloidal field (PF) coils
 - (3) central solenoid (CS) coils
 - (4) correction coils (CC)
- (b) vacuum vessel (VV)
- (c) in-vessel coil systems
- (d) in-vessel components, including blanket and divertor
- (e) cryostat
- (f) VV overpressure suppression system
- (g) thermal shields

Each of these major systems consists of other subsystems and components that together form a major part of the tokamak.

The tokamak has a confinement structure that also serves as a radiation-shielding barrier; the cryostat and the VV provide the vacuum boundaries. The primary purpose of the cryostat is to provide the environment for the thermal isolation of the superconducting magnets. The VV is located inside the magnet system and provides the first confinement barrier for the in-vessel radiological inventory.

The thermal shield is mounted between the VV and the superconducting magnets on the inside, and the cryostat and the magnets on the outside. All of these components are mounted inside the cryostat. Inside the VV, the internal replaceable components include blanket modules and divertor cassettes.

FAB-1210 Magnet System

The magnet system for the ITER tokamak consists of TF coils, a CS, PF coils, and, if necessary, CCs. The TF coils determine the basic toroidal segmentation of the machine and are chosen to meet the number and size requirements of access ports. A typical magnet system is shown in [Figure FAB-1210-1](#).


The TF coil case encloses the winding pack and is the main structural component of the magnet system. The TF coil case and the winding pack are structurally linked.

The CS assembly consists of a vertical stack of winding pack modules, which is supported from the bottom of the TF coils through its preload structure. The number of CS modules is designed to satisfy the plasma-shaping requirements.

The PF coils are attached to the TF coil to allow for radial displacements. The PF coils provide suitable magnetic fields for plasma shaping and position control.

Outside the TF coils are located, if necessary, independent sets of CCs, each consisting of coils arranged around the toroidal circumference. These coils may be used to correct error fields (particularly toroidal asymmetry) arising from positioning errors in the TF coils, CS, and PF coils.

Figure FAB-1210-1 Example of a Magnet Confinement System in an ITER Machine



GENERAL NOTE: Image adapted from Quora, <https://www.quora.com/What-are-the-pros-and-cons-of-controlled-nuclear-fusion-with-inertial-confinement-like-NIF-National-Ignition-Facility-versus-magnetic-confinement-like-ITER-or-TOKAMAK>.

The gravity supports are composed of pedestals with flexible elements to allow radial displacements. The magnets are supported fully independently of the vessel and associated components.

(a) The magnet system provides the following:

(1) TF coils for the magnetic field that gives the designer-specified plasma safety factor during the various phases of operation.

(2) TF coil structures that are integrated with the PF coil supports and the CS structures to restrain the electromagnetic loads on the coils under normal operating and fault conditions. The TF coil structures also resist the gravity and seismic loads of the magnet system.

(3) CS for the majority of the magnetic flux change needed to initiate the plasma, generate the plasma current, and maintain this current during the operation time. The CS contributes to the fields needed to control the plasma.

(4) PF coils for the magnetic fields that shape the plasma and control its position during the various phases of operation.

(5) CCs that compensate for field errors due to design asymmetries and geometric tolerances in the machine.

(b) The magnets must withstand the following conditions:

(1) electromagnetic loads acting on the magnets

(2) the weight of the magnets

(3) seismic loads on the magnets

(4) forces applied during installation and assembly of the magnets

(5) helium coolant pressure loads

FAB-1220 Magnet Structures

In a tokamak, the TF magnet is subjected to two main force systems. The in-plane loads are generated by the interaction of the current in the TF coils with the toroidal field. The out-of-plane loads are generated by the interaction of the current in the TF coils with the poloidal field. In most instances, the TF coil cases are the main structural component of the magnet system, and they provide support against the TF coil in-plane as well as out-of-plane loads.

FAB-1221 Magnet Structural Arrangement. The TF coil casing encloses the winding pack and is the main structural component of the magnet system. The TF coils are structurally linked. The coil case is fabricated from an engineering material, such as stainless steel or an equivalent material. The TF coil structures support the self-equilibrating electromagnetic forces acting between the TF coils, the CS, the PF coils, the CCs, and the VV during normal operation, plasma disruption, and fault events.

FAB-1300 VACUUM VESSEL

FAB-1310 Functional Requirements

The vacuum vessel

(a) provides a hazardous materials confinement barrier and withstands postulated accidents without losing confinement

(b) is designed to remove the nuclear heating and maintain the surface heat flux within the allowable temperature and stress limits

(c) is designed to remove the decay heat of in-vessel components, even in conditions when the other cooling systems are not functioning

(d) provides a pressure boundary consistent with the generation and maintenance of a high-quality vacuum

(e) supports in-vessel components to specified tolerances and their loads under normal and off-normal operations

(f) together with the in-vessel components, maintains a specified toroidal electrical resistance and contributes to plasma stability by providing a conductive shell tight fitting to the plasma as far as practically feasible

(g) together with the blanket, divertor, and ancillary equipment in ports, provides adequate radiation shielding for the superconducting coils and reduces activation inside the cryostat and at connecting ducts (end parts of the port extensions) to facilitate remote handling and decommissioning

(h) provides access ports or feed-throughs for in-vessel component service and maintenance, maintenance and inspection equipment, fueling and pumping systems, diagnostics, and plasma heating equipment and test blanket

The main components that make up the VV are the main vessel, the port structures, and the VV supporting system. The tokamak VV is a torus-shaped structure with shielding and coolant. The basic vessel design is an all-welded structure. Only the inner shell serves as the first confinement barrier when the double-wall structure is employed. The VV is divided into sectors joined by welding.

FAB-1320 Vessel Shells

The main vessel may consist of inner and outer shells, ribs and gussets, blanket module supporting structures, in-wall shielding, splice plates, port stubs, and special thick-wall components, such as the divertor support structures. Stiffening ribs between the shells provide the required mechanical strength and separate the shells of the structure.

The inner and outer shells and stiffening ribs are joined by welding. Each sector is subdivided into half-sectors, and these subdivisions are connected with pressure-tight central poloidal ribs.

FAB-1330 Port Structures

The VV may have upper, equatorial, and lower port structures, including local penetrations. There are ports for additional plasma heating systems, remote maintenance access to facilitate in-vessel component replacement and/or diagnostics, and vacuum pumping, etc. Between these ports, there are local penetrations for the divertor piping, the in-vessel viewing, and glow discharge.

The conducting shells that aid the plasma vertical stability may be mounted to the VV.

Most of the port components can be either single- or double-wall construction with stiffening ribs between the shells. Some components of the ports have a single-wall construction as a part of the structure. The connecting ducts may be composed of thinner shells with reinforcing beams. Local penetrations are usually thin shells.

FAB-1340 Supports and Mechanical Interfaces

A tokamak VV is vertically supported by sliding VV supports. These supports are horizontally restrained against fast displacements taking place during seismic events or fast transients but are free to move during thermal expansion. The VV is also restrained vertically in the upward and downward directions.

Tokamak blanket modules may be attached directly to the VV by a set of blanket module supports mounted to blanket module support structures located in the VV.

FAB-1341 Divertor Attachment. Divertors are supported by structures integrated with the shell of the VV.

FAB-1342 Port-Cryostat Interfaces. The port structures interface with the cryostat with bellows between the port-connecting ducts and the cryostat vessel. The local penetrations also interface with the cryostat with bellows.

FAB-1350 Cooling

The VV's primary heat transfer system consists of multiple loops so as to have redundancy of cooling capability.

The independent loops feed coolant to sectors of the VV to minimize the effect of faults. This limits the maximum possible VV temperature rise resulting from a coolant leak in one of the VV loops. During normal operation, the total heat deposition in the VV is mainly due to nuclear heating, and the heat is nonuniformly deposited in the VV.

During baking, the coolant temperature is increased to achieve the required baking conditions of the main vessel and ports.

FAB-1351 VV Coolant Routing. The coolant is supplied and flows within an internal supply structure. This structure distributes the coolant to channels on both the inboard and outboard sides of the vessel to provide a flow in the channels.

FAB-1360 Loading Conditions

The loads acting on the VV can be divided into four categories.

(a) *Inertial Loads.* These loads are due to accelerations due to gravity and seismic events.

(b) *Electromagnetic (EM) Loads.* These loads act on nearly all conductive structures during fast transients [e.g., plasma disruptions, plasma vertical displacement events (VDEs), and magnet current fast discharge].

(c) *Pressure Loads.* These loads include coolant and incidental VV internal and external pressure.

(d) *Thermal Loads.* These loads are caused by temperature gradients inside the VV structure caused by nuclear heating and thermal radiation, or by the temperature difference between the VV coolant and the blanket coolant.

Other types of loads are piping loads attached to the ports, coolant loop loading, and accident loads.

FAB-1400 IN-VESSEL COMPONENTS

FAB-1410 Divertor

(a) The divertor is a plasma-facing component that is positioned in the VV. The primary functions of the divertor are to

- (1) define the boundary of the plasma
- (2) enable the control of impurities
- (3) provide a means for nonradiant power fraction exhaust
- (4) provide a means for helium ash exhaust
- (5) protect the VV by absorbing neutrons
- (6) perform the heat transfer function

(b) To deliver the required functionality, the divertor shall sustain the following environmental effects and loading:

- (1) high heat flux
- (2) plasma-induced surface erosion
- (3) neutron-induced irradiation

(c) The geometrical design and features of the divertor can vary depending on the exact reactor application, e.g., a single-null or double-null configuration. However, most designs rely on active cooling. The divertor consists of a structural element that contains the coolant and an armor element that provides the required protection from the plasma interception.

FAB-1420 Blanket

(a) The blanket is a plasma-facing component that lines the majority of the VV. The primary function of the blanket is to extract the energy released from a fusion reaction.

This is executed through absorbing fusion neutrons into a fluid medium and then using this absorbed energy to generate electricity. In addition, the blanket provides the following functionality:

(1) generates tritium by reaction of the fusion neutrons with lithium or lithium compounds

(2) acts as a neutron multiplier, compensating for neutron loss and thus sustaining the fusion reactions

(3) protects the VV by absorbing fusion by-product neutrons and protects the VV from plasma heat and plasma particles

(b) To deliver the required functionality, the blanket shall sustain the following environmental effects and loading:

(1) heat flux

(2) plasma-induced surface erosion

(3) neutron-induced irradiation

(4) EM loads in plasma operation and from plasma transients

(c) The geometrical design and features of the blanket can vary depending on the blanket's exact reactor application. However, most designs rely on active cooling within a metallic structure.

FAB-1421 Blanket Coolant Manifolds. Coolant manifolds are routed over the vessel's plasma-side surface, branching to blanket modules. The coolant manifolds are routed by the cooling circuit.

SUBSECTION FB

PRESSURE BOUNDARY COMPONENTS

SUBPART FBA MAGNET

ARTICLE FBA-1000 INTRODUCTION

FBA-1100 SCOPE

FBA-1110 Aspects of Construction Covered by These Rules

(a) [Subsection FB](#) contains rules for the material, design, fabrication, examination, testing, overpressure relief, marking, stamping, and preparation of reports by the Certificate Holder of items that are intended to conform to the requirements for Class A construction.

(b) The rules of [Subsection FB](#) cover the requirements for strength and pressure integrity of items, the failure of which would violate the pressure-retaining boundary. The rules cover initial construction requirements but do not cover deterioration that may occur in service as a result of corrosion or instability of material.

ASME BPVC, Section III, Subsection NCA, NCA-1130 gives further limitations to the rules of this Subsection.

FBA-1120 Temperature Limits

The rules of [Subpart FBA](#) shall not be used for items that are to be subjected to metal temperatures that exceed the temperature limit in the Owner's Design Specification.

FBA-1130 Boundaries of Jurisdiction Applicable to This Subsection

FBA-1131 Boundary of Components. The Design Specification shall define the boundary of a component.

FBA-1132 Boundary Between Components and Attachments

FBA-1132.1 Jurisdictional Boundary. The jurisdictional boundary shall be defined in the Design Specification.

FBA-1140 Electrical and Mechanical Penetration Assemblies

Electrical and mechanical penetration assemblies shall be constructed in accordance with the rules for vessels, except that the design and the material performing the electrical conducting and insulating functions need not meet the requirements of this Subsection.

ARTICLE FBA-2000 MATERIAL

FBA-2100 GENERAL REQUIREMENTS FOR MATERIAL

FBA-2110 Scope of Principal Terms Employed

(a) The term “material” or “pressure-retaining material” as used in this Subsection is defined in (c) below.

(b) The term “material organization” is defined in ASME BPVC, Section III, Subsection NCA, Article NCA-9000.

(c) The term “material” as used in this Subsection applies to items such as vessel shells, heads, and nozzles; pipes, tubes, and fittings; valve bodies, bonnets, and disks; pump casings and covers; and bolting that joins pressure-retaining items.

(d) The requirements of this Article make reference to the term “thickness.” For the purpose intended, the following definitions of nominal thickness apply:

(1) *plate*: the plate thickness is the dimension of the short transverse direction.

(2) *forgings*: the thickness is the dimension defined as follows:

(-a) *hollow forgings*: the nominal thickness is measured between the inside and outside surfaces (radial thickness).

(-b) *disk forgings (axial length less than the outside diameter)*: the nominal thickness is the axial length.

(-c) *flat ring forgings (axial length less than the radial thickness)*: for axial length ≤ 2 in. (50 mm), the axial length is the nominal thickness. For axial length > 2 in. (50 mm), the radial thickness is the nominal thickness.

(-d) *rectangular solid forgings*: the least rectangular dimension is the nominal thickness.

(3) *castings*

(-a) thickness, t , for fracture toughness testing is defined as the nominal pipe wall thickness of the connecting piping.

(-b) thickness, t , for heat treatment purposes is defined as the thickness of the pressure-retaining wall of the casting, excluding flanges and sections designated by the designer as non-pressure retaining.

FBA-2120 Pressure-Retaining Material

FBA-2121 Permitted Material Specifications

(a) Pressure-retaining material shall conform to the requirements of one of the specifications for material given in ASME BPVC, Section II, Part D, Subpart 1, Tables 2A and 2B, including all applicable footnotes in the tables, or to those material specifications listed in this Article and to all of the requirements of this Article that apply to the product form in which the material is used.

(b) The requirements of this Article do not apply to material for items not associated with the pressure-retaining function of a component, such as shafts, stems, trim, spray nozzles, bearings, bushings, springs, and wear plates, nor to seals, packing, gaskets, valve seats, and ceramic insulating material and special alloys used as seal material in electrical penetration assemblies.

(c) Material made to specifications other than those specified in the Design Specification may be used for the following applications:

(1) safety valve disks and nozzles, when the nozzles are internally contained by the external body structure

(2) control valve disks and cages, when the valves function for flow control only

(3) line valve disks in valves whose inlet connections are NPS 2 (DN 50) and smaller

(d) Material for instrument line fittings and valves NPS 1 (DN 25) and smaller may be made to specifications other than those specified in the Design Specification.

(e) Welding and brazing material used in the manufacture of items shall comply with the Design Specification except as otherwise permitted in ASME BPVC, Section IX, and shall also comply with the applicable requirements of this Article. The requirements of this Article do not apply to material used as backing rings or backing strips in welded joints.

(f) The requirements of this Article do not apply to hard surfacing or corrosion-resistant weld metal overlay that is 10% or less of the thickness of the base material.

FBA-2122 Special Requirements Conflicting With Permitted Material Specifications. Special requirements stipulated in this Article shall apply in lieu of the requirements of the material specification whenever the special requirements conflict with the material specification requirements (see ASME BPVC, Section III, Subsection NCA,

NCA-3856). Where the special requirements include an examination, test, or treatment that is also required by the material specification, the examination, test, or treatment need be performed only once. Required nondestructive examinations shall be performed as specified for each product form. Any examination, repair, test, or treatment required by the material specification or by this Article may be performed by the Material Organization or the Certificate Holder. Any hydrostatic or pneumatic pressure test required by a material specification need not be performed, provided the material is identified as not having been pressure tested and it is subsequently pressure tested in the system, except where the location of the material in the component or installation would prevent performing any nondestructive examination required by the material specification subsequent to the hydrostatic or pneumatic test.

FBA-2123 Size Ranges. Material outside the limits of size or thickness given in any specification in ASME BPVC, Section II may be used if the material is in compliance with the other requirements of the specification and no size limitation is given in the rules for construction. In those specifications in which chemical composition, mechanical properties, or other load considerations such as electromagnetic load are indicated to vary with size or thickness, any material outside the specification range shall be required to conform to the composition and mechanical properties shown for the nearest specified range.

FBA-2124 Bolting Material

(a) Material for bolts and studs shall conform to the requirements of the specifications defined in the Design Specification. Material for nuts shall conform to ASME BPVC, Section II, Part A, SA-194 or to the specifications defined in the Design Specification.

(b) The use of washers is optional. When used, washers shall be made of wrought material with mechanical properties compatible with the nuts with which they are to be employed.

FBA-2130 Certification of Material

All material used in the construction of components shall be certified as required in ASME BPVC, Section III, Subsection NCA, NCA-3861 and NCA-3862. Certified Material Test Reports are required for pressure-retaining material except as provided by NCA-3861. A Certificate of Compliance may be provided in lieu of a Certified Material Test Report for all other material. Copies of all Certified Material Test Reports and Certificates of Compliance applicable to material used in a component shall be furnished with the material.

FBA-2140 Welding Material

For the requirements governing the material to be used for welding, see [FBA-2300](#).

FBA-2150 Material Identification

The identification of pressure-retaining material and materials welded thereto shall meet the requirements of ASME BPVC, Section III, Subsection NCA, NCA-3856. Material for small items shall be controlled during manufacture and installation of a component so that it is identifiable as acceptable material at all times. Welding and brazing materials shall be controlled during the repair of material and during manufacture and installation so that they are identifiable as acceptable until the material is actually consumed in the process.

FBA-2160 Deterioration of Material in Service

Consideration of deterioration of material caused by service is the responsibility of the Owner, who shall select material suitable for the conditions stated in the Design Specification with specific attention being given to the effects of service conditions on the properties of the material. Special consideration shall be given to the influence of the effects of irradiation on the properties of material. Any special requirement shall be specified in the Design Specification.

FBA-2170 Heat Treatment to Enhance Impact Properties

Carbon steels, low alloy steels, and high alloy chromium (series 4XX) steels may be heat treated by quenching and tempering to enhance their impact properties. Postweld heat treatment of components at a temperature of not less than 1,100°F (595°C) may be considered to be the tempering phase of the heat treatment.

FBA-2180 Procedures for Heat Treatment of Material

When heat-treating temperature or time is required by the material specification and the rules of this Subsection, the heat treating shall be performed in temperature-surveyed and temperature-calibrated furnaces or the heat treating shall be controlled by measurement of material temperature by thermocouples in contact with the material or attached to blocks in contact with the material or by calibrated instruments. Heat treating shall be performed under furnace-loading conditions such that the heat treatment is in accordance with the material specification and the rules of this Subsection.

FBA-2190 Non-Pressure-Retaining Material

(a) Material in the component support load path not performing a pressure-retaining function (see [FBA-1130](#)) that is welded to pressure-retaining material shall meet the requirements of [Article FBA-2000](#).

(b) Material not performing a pressure-retaining function and not in the component support load path (nonstructural attachments) welded at or within $2t$ of the pressure-retaining portion of the component, where t is defined in [FBA-2110\(d\)\(3\)](#), need not comply with [Article FBA-2000](#), provided all requirements within [Article FBA-2000](#) are met.

FBA-2200 MATERIAL TEST COUPONS AND SPECIMENS FOR FERRITIC STEEL MATERIAL**FBA-2210 Procedure for Obtaining Test Coupons and Specimens for Quenched and Tempered Material**

FBA-2211 General Requirements. The procedure for obtaining test coupons and specimens for quenched and tempered material is related to the product form. Coupon and specimen location and the number of tension test specimens shall be in accordance with the material specifications. References to dimensions signify nominal values.

FBA-2300 WELDING MATERIAL**FBA-2310 General Requirements**

(a) All welding material used in the construction and repair of components or material, except welding material used for cladding or hard surfacing, shall conform to the

requirements of the welding material specification or to the requirements for other welding material as permitted in ASME BPVC, Section IX. In addition, welding material shall conform to the requirements stated in this paragraph and to the rules covering identification in [FBA-2150](#).

(b) The Certificate Holder shall provide the organization performing the testing with the following information, as applicable:

- (1) welding process
- (2) SFA specification and classification
- (3) other identification if no SFA specification applies
- (4) minimum tensile strength
- (5) drop weight test for material as welded or as heat treated, or both
- (6) Charpy V-notch test for material as welded or as heat treated, or both; the test temperature and the lateral expansion or the absorbed energy shall also be provided
- (7) the preheat and interpass temperatures to be used during welding of the test coupon
- (8) postweld heat treatment time, temperature range, and maximum cooling rate, if the production weld will be heat treated
- (9) elements for which chemical analysis is required per the SFA specification or Welding Procedure Specification
- (10) minimum delta ferrite

FBA-2400 DIMENSIONAL STANDARDS

Dimensions of standard items shall comply with the standards and specifications listed in ASME BPVC, Section III, Subsection NCA, Table NCA-7100-1.

ARTICLE FBA-3000 DESIGN

FBA-3100 GENERAL DESIGN

FBA-3110 Loading Criteria

FBA-3111 Loading Conditions. The loadings that shall be taken into account in the design of a component include, but are not limited to, the following:

- (a) internal and external pressure
- (b) impact loads, including rapidly fluctuating pressures
- (c) weight of the component and normal contents under operating or test conditions, including additional pressure due to static and dynamic head of liquids
- (d) superimposed loads such as other components, operating equipment, insulation, corrosion-resistant or erosion-resistant linings, and piping
- (e) wind loads, snow loads, vibrations, and earthquake loads where specified
- (f) reactions of supporting lugs, rings, saddles, or other types of supports
- (g) temperature effects
- (h) electromagnetic loads

FBA-3112 Design Loadings. The TF coil (TFC) and TFC structures (TFCS) are subject to structural (mechanical) loads and thermal loads. The normal operating conditions of the TFC and TFCS include the following:

- (a) constant structural loads
 - (1) dead loads
 - (2) preload of the precompression rings at the top and bottom of the coil
 - (3) energization
- (b) constant thermal loads, such as cooldown

(c) variable structural loads that occur during operation

- (1) plasma pulsing
- (2) CS coil- and PF coil-related loads

FBA-3200 DESIGN BY ANALYSIS

This subarticle, which includes the following paragraphs, is in development:

FBA-3210	Design Criteria
FBA-3211	Basis for Determining Stresses
FBA-3212	Stress Analysis
FBA-3213	Derivation of Stress Intensities
FBA-3214	Derivation of Stress Differences
FBA-3215	Classification of Stresses
FBA-3220	Stress Limits for Other Than Bolts
FBA-3221	Design Loadings
FBA-3222	Level A Service Limits
FBA-3223	Level B Service Limits
FBA-3224	Level C Service Limits
FBA-3225	Level D Service Limits
FBA-3226	Testing Limits
FBA-3227	Applications of Plastic Analysis
FBA-3228	Design Stress Values
FBA-3230	Stress Limits for Bolts
FBA-3231	Design Conditions
FBA-3232	Design Stress Intensity Values

NONMANDATORY APPENDIX A TOPICS IN DEVELOPMENT

The following proposed Articles, Subparts, and Subsections are in development and may be included in future editions:

Article FBA-4000	Fabrication and Installation
Article FBA-5000	Examination
Subpart FBB	Vacuum Vessel
Subpart FBC	Target Chamber
Subsection FC	In-Vessel Components
Subsection FD	Material
Subsection FE	Support Structures
Subsection FF	Balance of Plant Equipment

INTENTIONALLY LEFT BLANK

ASME Services

ASME is committed to developing and delivering technical information. At ASME's Customer Care, we make every effort to answer your questions and expedite your orders. Our representatives are ready to assist you in the following areas:

ASME Press	Member Services & Benefits	Public Information
<i>Codes & Standards</i>	Other ASME Programs	Self-Study Courses
Credit Card Orders	Payment Inquiries	Shipping Information
IMEchE Publications	Professional Development	Subscriptions/Journals/Magazines
Meetings & Conferences	Short Courses	Symposia Volumes
Member Dues Status	Publications	Technical Papers

How can you reach us? It's easier than ever!

There are four options for making inquiries* or placing orders. Simply mail, phone, fax, or E-mail us and a Customer Care representative will handle your request.

<i>Mail</i>	<i>Call Toll Free</i>	<i>Fax—24 hours</i>	<i>E-Mail—24 hours</i>
ASME	US & Canada: 800-THE-ASME	973-882-1717	customercare@asme.org
150 Clove Road, 6th Floor	(800-843-2763)	973-882-5155	
Little Falls, New Jersey	Mexico: 95-800-THE-ASME		
07424-2139	(95-800-843-2763)		

*Customer Care staff are not permitted to answer inquiries about the technical content of this code or standard. Information as to whether or not technical inquiries are issued to this code or standard is shown on the copyright page. All technical inquiries must be submitted in writing to the staff secretary. Additional procedures for inquiries may be listed within.

I S B N 978-0-7918-7258-1



9 780791 872581



A 2 9 6 1 Q