


INTERNATIONAL STANDARD

**Conduit systems for cable management –
Part 21: Particular requirements – Rigid conduit systems**





THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.



IEC 61386-21

Edition 2.0 2021-04

INTERNATIONAL STANDARD

**Conduit systems for cable management –
Part 21: Particular requirements – Rigid conduit systems**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.120.10

ISBN 978-2-8322-9664-6

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	3
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 General requirements	5
5 General conditions for tests	5
6 Classification	5
7 Marking and documentation	5
8 Dimensions.....	6
9 Construction	7
10 Mechanical properties.....	7
11 Electrical properties	9
12 Thermal properties	9
13 Fire hazard	9
14 External influences	9
15 Electromagnetic compatibility	10
Annex A (normative) Classification coding for conduit systems	14
Annex B (normative) Determination of material thickness	14
Annex C (normative) Additional test requirements for conduit systems already complying with IEC 61386-1:2008	14
Annex AA (informative) Calculation for minimum and maximum rate of increase of force for 10.2.4	15
Figure 101 – Bending apparatus for metallic and composite conduits	10
Figure 102 – Gauge for checking the minimum inside diameter of the conduit system after impact, bending, collapse and resistance to heat tests	11
Figure 103 – Bending apparatus for non-metallic and composite conduit	12
Figure 104 – Arrangement for collapse test	13
Figure AA.1 – Graph showing force against time for 750 N force.....	15
Table 101 – Thread lengths	6
Table 102 – Maximum entry diameter and minimum entry length details	7
Table AA.1 – Minimum and maximum rate of increase of force for 10.2.4	16

INTERNATIONAL ELECTROTECHNICAL COMMISSION

CONDUIT SYSTEMS FOR CABLE MANAGEMENT –

Part 21: Particular requirements – Rigid conduit systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61386-21 has been prepared by subcommittee 23A: Cable management systems, of IEC technical committee 23: Electrical accessories:

This second edition cancels and replaces the first edition published in 2002. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Subclause 7.1.103 has been added requiring the manufacturer to declare whether the conduit is bendable;
- b) Annex AA has been added to provide guidance on the application of a constantly increasing force.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
23A/950/FDIS	23A/955/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 61386 series, published under the general title *Conduit systems for cable management*, can be found on the IEC website.

This document is to be used in conjunction with IEC 61386-1:2008 and IEC 61386-1:2008/AMD1:2017.

This document supplements or modifies the corresponding clauses of IEC 61386-1:2008 and IEC 61386-1:2008/AMD1:2017. Where a particular clause or subclause of IEC 61386-1:2008 and IEC 61386-1:2008/AMD1:2017 is not mentioned in this document, that clause or subclause applies as far as is reasonable. Where this document states "addition", "modification" or "replacement", the relevant text of IEC 61386-1:2008 and IEC 61386-1:2008/AMD1:2017 is to be adapted accordingly.

Subclauses, tables and figures which are in addition to those in IEC 61386-1:2008 and IEC 61386-1:2008/AMD1:2017 are numbered starting with 101. Annexes which are additional to those in IEC 61386-1:2008 and IEC 61386-1:2008/AMD1:2017 are lettered AA, BB, etc.

In this document, the following print types are used:

- Requirements proper: in roman type.
- *Test specifications: in italic type.*
- Explanatory matter: in smaller roman type.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

CONDUIT SYSTEMS FOR CABLE MANAGEMENT –

Part 21: Particular requirements – Rigid conduit systems

1 Scope

Clause 1 of IEC 61386-1:2008 is applicable, except as follows:

Addition:

This part of IEC 61386 specifies the requirements for rigid conduit systems.

2 Normative references

Clause 2 of IEC 61386-1:2008 and of IEC 61386-1:2008/AMD1:2017 are applicable, except as follows:

Addition:

IEC 61386-1:2008, *Conduit systems for cable management – Part 1: General requirements*
IEC 61386-1:2008/AMD1:2017

3 Terms and definitions

Clause 3 of IEC 61386-1:2008 and of IEC 61386-1:2008/AMD1:2017 are applicable.

4 General requirements

Clause 4 of IEC 61386-1:2008 is applicable.

5 General conditions for tests

Clause 5 of IEC 61386-1:2008 and of IEC 61386-1:2008/AMD1:2017 are applicable.

6 Classification

Clause 6 of IEC 61386-1:2008 is applicable, except as follows:

Classifications 6.1.1, 1; 6.1.2, 1; 6.1.3, 2; 6.1.3, 3; 6.1.3, 4; 6.1.4, 1; and 6.1.5, 1 are not applicable.

NOTE Rigid conduit systems according to 6.1.1, 2 and 6.1.2, 2 and classification 1 from 6.2.1, Table 1 are not allowed in France.

7 Marking and documentation

Clause 7 of IEC 61386-1:2008 and of IEC 61386-1:2008/AMD1:2017 are applicable, except as follows:

Addition:

7.1.101 The conduit shall be marked in accordance with 7.1 along its entire length at regular intervals of preferably 1 m but not longer than 3 m and each length shall be marked at least once.

Compliance is checked by inspection.

7.1.102 The manufacturer shall document, for the conduit system, the minimum inside diameter and the classification in accordance with Clause 6.

Compliance is checked by inspection of the documentation.

7.1.103 The manufacturer shall declare whether the conduit is bendable and provide all information, instructions and, if necessary, bending aids for proper and safe bending of the conduit.

Compliance is checked by inspection and by the tests specified in 10.4 and 10.6.

8 Dimensions

Replacement:

8.1 Threads and outside diameters shall comply with IEC 60423.

Compliance is checked by means of the gauges specified in IEC 60423.

8.2 Threadable conduits and threadable conduit fittings, except terminating conduit fittings, shall comply with Table 101. Non-threadable conduit fittings, except fittings which are part of a conduit system declaring tensile strength, shall comply with Table 102. The minimum inside diameter of the conduit system shall be as declared by the manufacturer.

Compliance is checked by measurement.

Table 101 – Thread lengths

Size	External thread	Internal thread
	Minimum length	Minimum length
mm	mm	mm
6	05,5	06,5
8	06,5	07,5
10	08,5	09,5
12	10,5	11,5
16	12,5	13,5
20	14,0	15,0
25	17,0	18,0
32	19,0	20,0
40	19,0	20,0
50	19,0	20,0
63	19,0	20,0
75	19,0	20,0

Table 102 – Maximum entry diameter and minimum entry length details

Size mm	Maximum entry diameter mm	Minimum entry length mm
6	06,5	06,0
8	08,5	08,0
10	10,5	10,0
12	12,5	12,0
16	16,5	16,0
20	20,5	20,0
25	25,5	25,0
32	32,6	30,0
40	40,7	32,0
50	50,8	42,0
63	63,9	50,0
75	75,9	50,0

9 Construction

Clause 9 of IEC 61386-1:2008 is applicable.

10 Mechanical properties

Clause 10 of IEC 61386-1:2008 and of IEC 61386-1:2008/AMD1:2017 are applicable, except as follows:

10.2 Compression test

Subclause 10.2 is applicable with the following addition:

10.2.4 Add the following note at the end of Subclause 10.2.4:

NOTE In order to achieve a uniformly increasing compression force, the force indicated in Table 4 is divided by time; this value is the required rate per second to fulfil the requirement.

Example: For a test force of 750 N an increase of the test force of 25 N/s is required (750 divided by 30 equals 25). Informative Annex AA gives detailed calculations including tolerances for time and force.

10.4 Bending test

Replacement:

Conduits which are declared by the manufacturer as being bendable are tested in accordance with 10.4.101, 10.4.102 or 10.4.103.

Addition:

10.4.101 Metallic conduits

10.4.101.1 *Conduit sizes 16, 20 and 25 are subjected to a bending test by means of the apparatus shown in Figure 101. Testing of other sizes is in accordance with the manufacturer's instructions.*

10.4.101.2 Samples having a length equal to 30 times the nominal diameter, are bent so that when released, they have an angle of $(90 \pm 5)^\circ$, so that the inside radius of the bend is equal to six times the nominal diameter.

10.4.101.3 For conduits with welded seams, six samples are tested, three with the seam on the outside of the bend, three with the seam on the side.

10.4.101.4 After the test:

- the basic material of the conduits and the protective coating of the conduits shall show no cracks visible to normal or corrected vision without magnification;
- seams, if any, shall not have opened;
- the section of the conduit shall not have distorted unduly.

The distortion of the section is checked as follows:

When the bent conduit is held in such a position that the straight portions are at an angle of approximately 45° to the vertical, one end of the sample pointing upwards and the other downwards, it shall be possible to pass the appropriate gauge as shown in Figure 102 through the sample under its own weight and without any initial speed.

10.4.102 Non-metallic conduits

10.4.102.1 Conduit sizes 16, 20 and 25 are subjected to a bending test by means of the apparatus shown in Figure 103. The length of the sample is $500 \text{ mm} \pm 10 \text{ mm}$. Testing of other sizes is in accordance with the manufacturer's instructions.

10.4.102.2 A bending aid, in the form of a coiled spring of square section metal wire, without burrs and having an overall diameter between 0,7 mm and 1,0 mm less than the specified minimum inside diameter of the conduit, or a bending aid recommended by the manufacturer, is inserted into each sample before bending.

10.4.102.3 The sample with the bending aid inserted is conditioned for at least 2 h in a refrigerator within which the temperature is maintained at the declared temperature as given in Table 1 with a tolerance of $\pm 2^\circ\text{C}$.

The test is carried out within $12 \text{ s} \pm 2 \text{ s}$ after the removal of the sample from the refrigerator.

10.4.102.4 Each sample is placed in position as shown in Figure 103, and held lightly in the groove of the former by means of the clamp. The sample is bent round the former by moving the bending rollers so that, when released, it has an angle of $(90 \pm 5)^\circ$. In this position, it shall be possible to remove the bending aid without damage to the sample or the aid.

After the test, the sample shall show no cracks visible to normal or corrected vision without magnification and it shall be possible to pass the appropriate gauge, as shown in Figure 102, through the sample under its own weight and without any initial speed.

10.4.103 Composite conduits

Composite conduits which are declared by the manufacturer as being bendable are tested both in accordance with 10.4.101 and 10.4.102, using new samples for each test.

The test is carried out at the declared temperature as given in Table 1 with a tolerance of $\pm 2^\circ\text{C}$.

10.5 Flexing test

Subclause 10.5 of IEC 61386-1:2008 is not applicable.

10.6 Collapse test

Replacement:

10.6.101 Metallic conduits

Metallic conduits are not subjected to a collapse test.

10.6.102 Non-metallic and composite conduits

10.6.102.1 *Conduits which are declared by the manufacturer as being bendable shall be tested in accordance with 10.6.102.2. Before the test, conduits are bent in accordance with 10.4.102 with the exception of 10.4.102.3.*

10.6.102.2 *The samples are fixed to a rigid support by means of four straps, as shown in Figure 104, after having removed the bending spring or any other bending aids recommended by the manufacturer.*

The support with the sample in position is kept for $24\text{ h} \pm 15\text{ min}$ in a heating cabinet at the declared temperature as given in Table 2 with a tolerance of $\pm 2\text{ }^{\circ}\text{C}$.

After this period, with the support in such a position that the straight portions of the sample are at an angle of approximately 45° to the vertical, one end of the sample pointing upwards and the other downwards, it shall be possible to pass the appropriate gauge, as shown in Figure 102, through the sample under its own weight and without any initial speed.

10.7 Tensile test

Subclause 10.7 of IEC 61386-1:2008 is applicable, except as follows:

10.7.3 Not applicable.

11 Electrical properties

Clause 11 of IEC 61386-1:2008 and of IEC 61386-1:2008/AMD1:2017 are applicable.

12 Thermal properties

Clause 12 of IEC 61386-1:2008 is applicable, except as follows:

12.3 *Replacement:*

The load is then removed and immediately after its removal it shall be possible to pass the appropriate gauge, as shown in Figure 102, through the conduit under its own weight and without any initial speed, with the sample in the vertical position.

13 Fire hazard

Clause 13 of IEC 61386-1:2008 and of IEC 61386-1:2008/AMD1:2017 are applicable.


14 External influences

Clause 14 of IEC 61386-1:2008 and of IEC 61386-1:2008/AMD1:2017 are applicable.

15 Electromagnetic compatibility

Clause 15 of IEC 61386-1:2008 and of IEC 61386-1:2008/AMD1:2017 are applicable.


Addition:



Size	Bending radius		Radius of groove <i>r</i>
	Inside radius <i>R</i>	Outside radius <i>R</i> ₁	
mm	mm	mm	mm
16	96	113	8,1
20	120	141	10,1
25	150	178	12,7

NOTE This drawing is not intended to govern design except as regards the dimensions shown.


Figure 101 – Bending apparatus for metallic and composite conduits



D	80 % of the manufacturer's declared minimum inside diameter of the conduit system
Material	Steel, hardened and polished, edges slightly rounded
Manufacturing tolerance	+0,05 mm
Tolerance and axial dimension	0 ±0,2 mm
Admissible wear	0,01 mm

NOTE The drawing is not intended to govern design except as regards the dimensions shown

Figure 102 – Gauge for checking the minimum inside diameter of the conduit system after impact, bending, collapse and resistance to heat tests



IEC


Key

- 1 Bending roller
- 2 Clamp
- 3 Sample
- 4 Bending spring
- 5 Former
- 6 Section A – A

Size	Radius to bottom of groove of former	Radius of arc traced out by centre of bending roller	Radius of groove of former and bending roller	Diameter to bottom of groove of bending roller
mm	R_1 mm	R_2 mm	r mm	D mm
16	48	84	8,1	24
20	60	105	10,1	30
25	75	131,25	12,6	37,5

NOTE This drawing is not intended to govern design except as regards the dimensions shown.

Figure 103 – Bending apparatus for non-metallic and composite conduit



IEC

Key

- 1 Sample
- 2 Rigid support

NOTE This drawing is not intended to govern design except as regards the dimensions shown.

Figure 104 – Arrangement for collapse test

Annex A
(normative)

Classification coding for conduit systems

Annex A of IEC 61386-1:2008 is applicable.

Annex B
(normative)

Determination of material thickness

Annex B of IEC 61386-1:2008 is applicable.

Annex C
(normative)

**Additional test requirements for conduit systems
already complying with IEC 61386-1:2008**

Annex C of IEC 61386-1:2008 and of IEC 61386-1:2008/AMD1:2017 are applicable.

Addition:

Annex AA (informative)


Calculation for minimum and maximum rate of increase of force for 10.2.4

The following information is provided to assist test engineers calculate the required rate of increase of force vs time for compression test machines which have tolerances on the rate of load application.

Calculations for minimum and maximum rate of increase of force for 10.2.4:

- minimum rate equals minimum force (Table 4) divided by maximum time (33 s);
- nominal rate equals nominal force (Table 4) divided by nominal time (30 s);
- maximum rate equals maximum force (Table 4 +4 %) divided by minimum time (27 s).

For 750 N force, this can be shown by Figure AA.1 as force (N) against time (s).



Key

Line 1. is maximum rate

Line 2. is minimum rate

Figure AA.1 – Graph showing force against time for 750 N force

For all force levels, the calculations are as given in Table AA.1.

Table AA.1 – Minimum and maximum rate of increase of force for 10.2.4

Compression force (N)	Rate (N/s)		
	Minimum	Nominal	Maximum
125	3,8	4,2	4,8
320	9,7	10,7	12,3
750	22,7	25,0	28,9
1 250	37,9	41,7	48,1
4 000	121,2	133,3	154,1

